

T = Time pump is running  
V = Volume dispensed (litres)  
# = Number of drops



BAMBI MODEL		FOAM CONCENTRATION										SACK SIZE
		0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%	0.9%	1.0%	
6072	T	2	4	6	8	10	12	14	16	18	20	12 USG 45 L
	V	0.27	0.54	0.82	1.10	1.36	1.67	1.96	2.25	2.50	2.81	
	#	166	83	55	41	33	27	23	20	18	16	
8096	T	3	5	8	11	13	16	19	21	24	27	
	V	0.36	0.73	1.10	1.45	1.80	2.25	2.65	3.00	3.46	3.75	
	#	125	62	41	31	25	20	17	15	13	12	
9011	T	3	6	9	12	15	18	21	24	27	30	
	V	0.41	0.83	1.25	1.67	2.14	2.50	3.00	3.46	3.75	4.50	
	#	109	54	36	27	21	18	15	13	12	10	
1012	T	3	6	9	13	16	19	23	26	29	33	
	V	0.45	0.90	1.36	1.80	2.25	2.81	3.21	3.75	4.09	4.50	
	#	100	50	33	25	20	16	14	12	11	10	
1214	T	4	8	12	15	19	23	27	31	35	39	
	V	0.53	1.07	1.61	2.14	2.65	3.21	3.75	4.50	5.00	5.63	
	#	85	42	28	21	17	14	12	10	9	8	
1518	T	5	10	15	20	25	30	35	40	45	50	
	V	0.68	1.36	2.05	2.81	3.46	4.09	5.00	5.63	6.43	7.50	
	#	66	33	22	16	13	11	9	8	7	6	
1821	T	6	12	17	23	29	35	41	46	52	58	
	V	0.79	1.61	2.37	3.21	4.09	5.00	5.63	6.43	7.50	9.00	
	#	57	28	19	14	11	9	8	7	6	5	
2024	T	3	5	8	11	13	16	19	21	24	27	30 USG 114 L
	V	0.91	1.84	2.78	3.68	4.56	5.70	6.71	7.60	8.77	9.50	
	#	125	62	41	31	25	20	17	15	13	12	
2226	T	3	6	9	12	14	17	20	23	26	29	
	V	0.99	2.00	3.00	4.07	4.96	6.00	7.13	8.14	9.50	10.36	
	#	115	57	38	28	23	19	16	14	12	11	
2732	T	4	7	11	14	18	21	25	28	32	36	
	V	1.23	2.48	3.68	4.96	6.33	7.60	8.77	10.36	11.40	12.67	
	#	93	46	31	23	18	15	13	11	10	9	
320C	T	5	9	14	19	23	28	33	37	42	47	
	V	1.61	3.26	4.96	6.71	8.14	10.36	11.40	14.25	16.29	16.29	
	#	71	35	23	17	14	11	10	8	7	7	
3542	T	5	9	14	19	23	28	33	37	42	47	
	V	1.61	3.26	4.96	6.71	8.14	10.36	11.40	14.25	16.29	16.29	
	#	71	35	23	17	14	11	10	8	7	7	
420B	T	6	12	18	24	29	35	41	47	53	59	
	V	2.04	4.07	6.33	8.14	10.36	12.67	14.25	16.29	19.00	22.80	
	#	56	28	18	14	11	9	8	7	6	5	
4453	T	6	12	18	24	29	35	41	47	53	59	
	V	2.04	4.07	6.33	8.14	10.36	12.67	14.25	16.29	19.00	22.80	
	#	56	28	18	14	11	9	8	7	6	5	
5566	T	3	5	8	11	13	16	19	22	24	27	72 USG 272 L
	V	2.50	5.04	7.56	10.07	12.95	15.11	18.13	20.92	22.67	27.20	
	#	109	54	36	27	21	18	15	13	12	10	
680K	T	3	6	8	11	14	17	19	22	25	28	
	V	2.59	5.23	7.77	10.46	12.95	16.00	18.13	20.92	24.73	27.20	
	#	105	52	35	26	21	17	15	13	11	10	
6578	T	3	6	10	13	16	19	22	25	29	32	
	V	2.96	5.91	9.07	11.83	15.11	18.13	20.92	24.73	27.20	30.22	
	#	92	46	30	23	18	15	13	11	10	9	
7590	T	4	7	11	15	18	22	26	29	33	37	
	V	3.40	6.80	10.46	13.60	17.00	20.92	24.73	27.20	34.00	34.00	
	#	80	40	26	20	16	13	11	10	8	8	
HL4000	T	4	9	13	17	22	26	30	35	39	43	
	V	4.06	8.24	12.36	17.00	20.92	24.73	30.22	34.00	38.86	45.33	
	#	67	33	22	16	13	11	9	8	7	6	
HL5000	T	5	11	16	22	27	32	38	43	48	54	
	V	5.04	10.07	15.11	20.92	27.20	30.22	38.86	45.33	45.33	54.40	
	#	54	27	18	13	10	9	7	6	6	5	
HL7600	T	4	8	12	16	20	24	29	33	37	41	110 USG 500 L
	V	9.09	18.52	27.78	38.46	45.45	55.56	71.43	83.33	83.33	100.00	
	#	55	27	18	13	11	9	7	6	6	5	
HL9800	T	5	11	16	21	27	32	37	42	48	53	
	V	11.90	23.81	35.71	50.00	62.50	71.43	83.33	100.00	125.00	125.00	
	#	42	21	14	10	8	7	6	5	4	4	